

시험성적서 (Test Report)

 한국기계연구원 KOREA INSTITUTE OF MACHINERY & MATERIALS	Page(2) / Total Pages(60)	
--	---------------------------	--

1	시험명 Name of Test	내진형 최저소비효율 유입변압기 내진시험 Seismic Test of Minimum Energy Performance Standard Oil Transformer
2	의뢰자명 및 주소 Name and Address of Client	KOC 전기 (주) 대표자 : 황 희 술 부산광역시 강서구 녹산산단77로 6 KOC Elcetric Co., Ltd. 6, Noksansandan 77-ro, Gangseo-gu, Busan
3	제조사명 및 주소 Name and Address of Maker	KOC 전기 (주) 대표자 : 황 희 술 부산광역시 강서구 녹산산단77로 6 KOC Elcetric Co., Ltd. 6, Noksansandan 77-ro, Gangseo-gu, Busan
4	시험품 Test Specimen	1) 품명/모델명 내진형 최저소비효율 유입변압기 / HL1-1000 2) 사양 3상 60 Hz 1 000 kVA 22.9 / 0.38 kV Dyn11 1) Name/Model Minimum Energy Performance Standard Oil Transformer / HL1-1000 2) Specification 3P 60 Hz 1 000 KVA 22.9 / 0.38 kV Dyn11
5	시험방법 (Test Method)	Seismic Test Plan, STP-KOCE-KOM4770-01 (IEEE Std 693-2005: IEEE Recommended Practice for Seismic Design of Substations (High Required Response Spectrum x 2 (1.0g))
6	시험일자 (Test Date)	2018.09.19.
7	시험환경 (Test Environment)	온도(Temperature) : (27 ± 1) °C, 습도(Humidity) : (59 ± 7) % R.H.
8	시험결과 (Test Results)	본 시험품은 적용규격에서 요구하는 내진시험 기준에 부합함을 확인하였음. (It is confirmed that the specified specimen has conformed with requirements of seismic test according to the specifications.)
9	성적서 번호 (Report No.)	KIMM-18-0736
10	성적서 용도 (Use of Report)	품질평가용 (for Quality Evaluation)
11	기타사항 (Remarks)	시험결과 참조 (Refer to Test Results)
12	시험 및 보고 : Tested and Reported by :  시험실무자 : 박 진 우 Test Engineer : Jin-Woo Park	검토 및 승인 : Reviewed and Approved by :  기술책임자 : 정 병 창 Technical Manager : Byungchang Jung Ph.D

2018.09.28.

한국기계연구원 장 (인)

Korea Institute of Machinery & Materials

